LISTING SERVICE

LISTING No.   7300-1565:105   Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Pyro-Chem, One Stanton Street, Marinette, WI 54143-2542
Contact: Lyle McDonald (715) 735-7411 Fax (715) 732-3634

DESIGN: Models Triton Ext. (551472) and (551473) Notification Appliance Circuit (NAC) Power Extenders. Refer to listee's data sheet for detailed product description and operational considerations. For use with the following separately listed TEPG-US (CSFM Listing No. 7300-1597:117) system components:

430676	NAC Option Card
430677	Class A Adaptor

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

The system must be fully supervised and must have the secondary power supply capable of operating the system for at least 24 hours battery standby) in the normal condition and followed by not less than 5 minutes of alarm as required by code.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as notification appliance circuit power extenders for use with listee's separately listed fire alarm control units. Refer to listee's Installation Instructions Manual for details.

XLF: 7300-0026:214

04-18-03KK

Date Issued: **JUNE 17, 2003**   *Listing Expires June 30, 2004*

Authorized By: **DIANE K. AREND**, *Senior Deputy*
Program Manager